



Systematic Controls Corp

3105 Carter Circle • Kennesaw, GA 30144
Phone (770) 423-7100 Fax (770) 499-7483

CONNECTIONS FOR CHANGING FROM MX7 TO MX7-10

CONNECT POWER TO TERMINALS 1 AND 2

CONNECT AL-1 TO TERMINALS 3 AND 4

CONNECT AL-2 TO # 8 COMMON

9 N. O.

10 N. C.

CONNECT THERMOCOUPLE TO # 13 +

14 -

IF USING RTD, THEN # 11 A

13 B

14 B

4-20 OUTPUT IS # 6 +

7 -

4-20 RETRANSMIT IS # 18 -

19 +